

# New England Service Company

37 Northwest Drive  
Plainville, CT 06062  
860 747-1665 860 747-2536 fax

## Fire Hydrant Inspection Report

Owner of Hydrant: \_\_\_\_\_ Hyd. # \_\_\_\_\_  
Mailing Address: \_\_\_\_\_  
\_\_\_\_\_

Contact: \_\_\_\_\_

Location of Hydrant: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Make: \_\_\_\_\_ Size: \_\_\_\_\_  
Depth of Bury: \_\_\_\_\_ Color: \_\_\_\_\_  
Nozzles: \_\_\_\_\_ Inspected By: \_\_\_\_\_  
Inspection Date: \_\_\_\_\_

Inspector's CT Distribution II License Number: \_\_\_\_\_

Hydrant Pressurized Test: Pass  Fail  Reason for failure: \_\_\_\_\_

Static Pressure: \_\_\_\_\_ psi \_\_\_\_\_

Hydrant Flow Test: Pass  Fail  Reason for failure: \_\_\_\_\_

Nozzle Inspection: Pass  Fail  Reason for failure: \_\_\_\_\_

Nozzle Lubricated: Yes  No  Comments: \_\_\_\_\_

Is Hydrant Clear of Debris?: Yes  No  Comments: \_\_\_\_\_

Hydrant Painted: Yes  No  Comments: \_\_\_\_\_

Distance to Aux. Valve \_\_\_\_\_ FT \_\_\_\_\_ IN  
(From Hyd. To Valve)

Aux. Valve Working Cond.: Closes Tight  Comments: \_\_\_\_\_

Does Not Hold

Valve Box and Cover OK  Comments: \_\_\_\_\_

Damaged

Additional Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_